



IAQ INTERFACE MODULE

ISU NUMBER	SETTING
172	2
176	2
190	0
200	1
210	0
240	3
250	3
342	1
345*	1
350*	30
379	1
580*	2

NOTES:
 * Indicates user preference
 Other parameters selected as needed.

- W1 O/B
- W2 AUX
- W3 AUX2
- Y
- Y2
- G
- L
- OUT1
- OUT2
- IN1
- IN2
- DATS1
- DATS2

- C
- L
- R
- Y1
- Y2
- O
- W2

- Y1
- O

- C
- DEHUM
- R
- G
- Y2
- W1
- W2

**C7089U1006
 OUTDOOR SENSOR**

Title: Heil Variable 4H/2C Heat Pump with VisionPro IAQ utilizing dehumidification	
Author:	
Date:	Sheet:
Revision: 12.08	